

## IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

## CB TEST CERTIFICATE

Product

Surge Protective Devices

Name and address of the applicant

Signify Netherlands B.V.  
High Tech Campus 48, 5656 AE Eindhoven  
Netherlands

Name and address of the manufacturer

Signify Netherlands B.V.  
High Tech Campus 48, 5656 AE Eindhoven  
Netherlands

Name and address of the factory

*Note: When more than one factory, please report on page 2*

Ratings and principal characteristics

Test class III / Type 3, IP20  
Uc: 255 V~, Uoc: 10 kV, Isccr: 1000 A;  
Surge Protector Class I:  
Up L-N: ≤ 1,5 kV, Up L(N)-GND: ≤ 2 kV;  
Surge Protector Class II:  
Up L-N: ≤ 1,5 kV

Trademark / Brand (if any)

PHILIPS

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

Surge Protector Class I, Surge Protector Class II

Additional information (if necessary may also be reported on page 2)

☐ Additional information on page 2

A sample of the product was tested and found to be in conformity with

IEC 61643-11:2011

National differences:

EU Group Differences

As shown in the Test Report Ref. No. which forms part of this Certificate

6166177.50

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.  
Meander 1051  
Arnhem, 6825 MJ  
Netherlands

Date: 2023-08-11

Signature: Kate Xu

Additional factory

---

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.  
Meander 1051  
Arnhem, 6825 MJ  
Netherlands



Date: 2023-08-11

Signature: Kate Xu